

Yearly Benchmark Parameter for Daltonganj Town

Sl. No.	Particulars	2001-02	2002-03	2003-04	2004-05	2005-06	2006-07	2007-08
1	Energy input in MU	32.02	31.49	28.65	44.82	46.3	43.59	
2	Energy metered in MU	4.39	4.28	4.01	7.02	6.68	6.92	
3	Energy Billed	10.85	10.67	9.71	15.26	13.81	13.80	
4	Revenue Billed in Crores	4.53	3.00	3.24	4.09	4.08	4.54	
5	Revenue Realised in Crores	2.67	3.01	3.04	4.15	4.13	4.42	
6	Energy Realised in MU	6.40	10.71	9.11	15.50	13.98	13.44	
7	Avg. cost of supply (ACS)	4.82	4.82	4.82	4.82	6.88	6.88	
8	ARR (Rs./ Unit)	0.83	0.96	1.06	0.93	0.89	1.02	
9	No. of 11 kV feeders	6	6	6	6	6	6	
10	No. of feeder trippings	10950	13140	13140	12798	12970	13692	
11	Tripping duration in Hours	10257	11023	9563	8316	40998	7476	
12	DT failure rate (%)	26	27	26	30	5.03	24.26	
13	AT &C Losses (%)	80.03	66	68.2	65.42	69.8	69.16	
14	Total Man power strength	40	40	38	34	31	31	
15	Consumer complaints (Nos.)	8600	8800	8900	9600	5300	5750	
16	Complaint disposal time (Hr.)	3-4	3-4	2-3	2-3	2-3	2-3	
17	HT/LT Ratio	1:3.7	1:3.7	1:3.84	1:3.57	1:2.28	1:3.5	
18	Avg. load factor on DTR	0.35	0.32	0.27	0.34	0.32	0.45	
19	Avg. power factor	0.87	0.86	0.86	0.90	0.90	0.90	