

Yearly Benchmark Parameter for Deoghar Town

| Sl. No. | Particulars | 2001-02 | 2002-03 | 2003-04 | 2004-05 | 2005-06 | 2006-07 | 2007-08 |
|---------|-------------------------------|---------|---------|---------|---------|---------|---------|---------|
| 1 | Energy input in MU | | 88.53 | 103.4 | 95.88 | 86.82 | 89.1 | |
| 2 | Energy metered in MU | | 27.31 | 33.34 | 32.56 | 35.83 | 8.52 | |
| 3 | Energy Billed | | 28.88 | 34.83 | 34.41 | 39.70 | 41.58 | |
| 4 | Revenue Billed in Crores | | 9.11 | 9.19 | 9.48 | 10.09 | 10.45 | |
| 5 | Revenue Realised in Crores | | 5.64 | 7.27 | 6.90 | 7.22 | 8.98 | |
| 6 | Energy Realised in MU | | 17.88 | 27.55 | 25.06 | 28.43 | 35.73 | |
| 7 | Avg. cost of supply (ACS) | | 4.82 | 4.82 | 4.82 | 6.88 | 6.88 | |
| 8 | ARR (Rs./ Unit) | | 0.64 | 0.70 | 0.72 | 0.83 | 1.01 | |
| 9 | No. of 11 kV feeders | | 6 | 6 | 6 | 7 | 7 | |
| 10 | No. of feeder trippings | | 9988 | 10410 | 8813 | 7930 | 5953 | |
| 11 | Tripping duration in Hours | | 5000 | 2603 | 3248 | 3722 | 3753 | |
| 12 | DT failure rate (%) | | 34.46 | 19.58 | 19.5 | 18.31 | 17.35 | |
| 13 | AT &C Losses (%) | | 79.8 | 73.35 | 73.87 | 67.26 | 59.9. | |
| 14 | Total Man power strength | | 89 | 75 | 66 | 66 | 60 | |
| 15 | Consumer complaints (Nos.) | | 3600 | 3300 | 3290 | 1360 | 2413 | |
| 16 | Complaint disposal time (Hr.) | | 3-4 | 3-4 | 3-4 | 2-2.5 | 1-1.5 | |
| 17 | HT/LT Ratio | | 1:3 | 1:2.98 | 1:2.79 | 1:2.78 | 1:2.008 | |
| 18 | Avg. load factor on DTR | | 0.50 | 0.51 | 0.56 | 0.56 | 0.57 | |
| 19 | Avg. power factor | | 0.85 | 0.86 | 0.85 | 0.84 | 0.84 | |